BENTON COUNTY HEALTH DEPARTMENT

OFFICIAL STOP ORDER

Orde	r Dated October 27, 2022]	Permit]	None None
Nam	e Eagle Bay POA						
Addr	ess 28451 Northwoods Drive.						
	Lincoln, MO 65338						
Section	on 31 Township 41N	Range	_20W				
None, reason	are hereby notified that all work of at the above-mentioned location or reasons listed below: No permit obtained for installati (Section 5.01) Substandard materials used (Section 11-11.01A) Determined as a health hazard be (Section 3.05) Construction does not meet the installation does not meet the interpretation of the control of the	on of the so by the Heal ntent or protent or protent	nmediately sto eptic system th Official ovision of this	opped (Section s issued permit	11 of Ordina		
_							

Comment: On April 6 2022 I completed a site visit to the "Dump Station" located at PID: 099031001003059000. The inspection revealed that power had recently been cut from the pole to the aerator and effluent was surface discharging proximal to the tank outlet. The nearby ground surface was also spongy and saturated only in that area. This stop order may be lifted following the ATU working status be professionally addressed along with the field downstream that will most likely require permitting to bring to working order. It is strongly suggested that DNR be included in the progress of OWTS involving dumping and treatment. If calculations for sizing the dump station exceed 3000 gallons per day then DNR has jurisdiction over the system.

Failure to heed this STOP ORDER will be in violation of the Wastewater Treatment System Ordinance 1991-1. This order shall become final unless a request for a hearing as provided in Section 19 of this Ordinance is made within ten (10) working days from the date of service of the order. By Order of the County Health Official

EPHS/Authorized Health Representative